

ADMINISTRATOR'S REPORT

1-5-15 through 1-18-15

Waste Water Treatment Plant

- Sewer Plant running fine, nothing new to report.
- The air handling unit for the screen building has been repaired.
- The septage receiving pump has been completely rebuilt and should be in good shape for the foreseeable future.
- Continued with daily testing and other normal maintenance.

Sanitary Sewer Collection System

- Monthly service to the system is being done as time permits.

Water System & Plant

- We continue to perform normal maintenance at the plant.
- Had a few problems with our Asco Valves in the plant in multiple locations. These were easily resolved and did not affect the operation of the plant.
- We did have a mainline leak near N. Delaware and Lee St. this was quickly repaired during normal working hours
- Other than the normal meter and curb box repairs all things in town has been normal.

Other issues

- Nothing new to report

Recreation / Pool

- Closed for the season.

Street / Storm Sewer

- Cold patching of the pot holes around town over the past two weeks continues. This work is ongoing.
- We received the engineering agreement from CSX and the invoice for an additional \$2,066.00 for the engineering review. Nothing is for certain with these guys and the cost of the project will be over budget due to the endless red tape with CSX and with no recourse.

Development

- **Nothing new to report**

The service department staff has been doing a great job. Everyone has been willing to pitch in where necessary outside of their normal daily work routine and especially on Tue and Wed helping with the trash pick. With the weather and snow along the roadway trash pickup has become treacherous, tiring and dangerous.

Prepared by

Dan Rogers, Village Administrator

1-16-15